

[Home](#) ■ [Soluciones](#) ■ [Eficiencia energética](#) ■ [Wastewater Collection and Treatment](#) ■ [Effluent Filtration](#)

Energy-Efficient Effluent Filtration





Effluent filtration serves for increased removal of suspended solids (SS), BOD, COD, phosphorus (P) and nitrogen (N). About 20 % of German effluent is filtered.

The following filters are in common use:

- Multi-layer and multi-chamber sand filters with periodic water and air backwashing consume around 2.0 kWh/(PE•a) power;
- Continuous moving bed sand filter (e.g. our [CONTIFLOW® Sandfilter CFSF](#)) consume about 1.5 kWh/(PE•a);
- Microstrainers with a mesh size of 10 – 100 micron (e.g. our [RoDisc® Rotary Mesh Screen](#)) consume ca. 1.0 kWh/(PE•a);
- [Membrane Bio-Reactors](#) perform not only biological treatment, but also excellent filtration.

Where precipitation or flocculation is required, sand filters should be provided. Multi-layer sand filters are used at large wastewater plants, while continuous sand filters are more economic at small to medium-size plants.

Microstrainers are less effective than sand filters, but they are significantly less expensive and consume less power.

The following table provides a comparison:

	CONTIFLOW® Sandfilter CFSF		Microstrainer RoDisc® Rotary Mesh Screen	
SS feed concentration	20 mg/l	60 mg/l	20 mg/l	60 mg/l
SS effluent conc.	< 3 mg/l	< 10 mg/l	< 5 mg/l	< 15 mg/l
Power consumption at peak flow	≈ 10 Wh/m ³	≈ 12 Wh/m ³	≈ 4 Wh/m ³	≈ 6 Wh/m ³

Huber Technology Perú S.A.C.
RUC 20603308442

Phone in Chile: (+562) 220 803 34

Email: info@huber.pe
Internet: www.huber.pe

Member of the HUBER group:
www.huber.de
